



NOTE:

1. CULVERT MUST BE SIZED TO ACCOMMODATE FLOWS GENERATED DURING A 25-YR FLOOD EVENT
2. ANY DEVIATIONS FROM THESE STANDARDS MUST BE APPROVED BY THE CITY ENGINEER

FINISHED FLOOR ELEVATION TO BE SET BY DRIVEWAY GRADES

EXAMPLE:

$$L1 = 10' \quad L2 = 15' \quad L3 = 100' \quad DPELEV = 200'$$

$$\begin{aligned}
 FFE &= DP + (L1 * -0.03) + (L2 * 0.03) + (L3 * 0.10) \\
 &= 200 + (10' * -0.03) + (15' * 0.03) + (100' * 0.10) \\
 &= 200 - 0.3' + 0.45' + 10' \\
 &= 210.15''
 \end{aligned}$$

City Of Steamboat Springs Public Works Department	INCLINED DRIVEWAY	
	Drawn by: BSB	
PO BOX 775088 STEAMBOAT SPRINGS, CO (970) 871-8216 FAX (970) 871-6306	Scale: N.T.S.	Date: 7/13/06
	Revision description:	
	Sheet number of	

This document was created with Win2PDF available at <http://www.win2pdf.com>.
The unregistered version of Win2PDF is for evaluation or non-commercial use only.