



FIRE PREVENTION SERVICES

P. O. Box 775088 / 927 Oak Street, Steamboat Springs, CO 80477
(970) 879-2060 ext. 217

Fax: (970) 871-6306

Proudly serving the City of Steamboat Springs and the Steamboat Springs Rural Fire Protection District

**CARNIVALS / FAIRS
PERMIT / INSPECTION FORM**

NAME: _____
ADDRESS: _____
PHONE #: _____

PERMIT #: _____
TYPE OF EVENT: _____
LOCATION OF EVENT: _____

- _____ 1. Does the operator of the event have all necessary documents, and prior approval from the City and County.
- _____ 2. **Section 2403.81 Access.** Fire apparatus access roads shall be in accordance with Section 503. (24' wide with 48' turning radius).
- _____ 3. **Section 2403.8.5 Fire Break** An unobstructed passageway not less than 12 feet shall be maintained on all sides of structure as required by the Chief.
- _____ 4. **Section 2404.12 Portable Fire Extinguisher.** A minimum of one fire extinguisher with a rating of not less than 2-a:10b:c shall be provided. Maximum travel distance to a portable fire extinguisher shall not exceed 75 feet. A class K- rated fire extinguisher shall be provided where deep-fat fryers are used.
- _____ 5. **Section 2404.15.7 Electrical equipment.** Electrical equipment and installations shall comply with the ICC Electrical Code.
- _____ 6. **Section 2404.15.3 Location.** Cooking and heating equipment shall not be located within 10 feet of exits or combustible materials.
- _____ 7. **Section 2404.18.5.2 Fueling.** Refueling shall be performed outside of the structure in accordance with Section 2404.17.2.
- _____ 8. **Section 2404.19 Separation of Generators.** Internal combustion power sources shall be isolated from combustible structures a minimum of 20 feet and isolated from contact with the public by either physical guards, fencing or an enclosure.
- _____ 9. All tents, canopies, and temporary membrane structures shall be in accordance with Chapter 24 of the International Fire Code.
- _____ 10. All flammable and combustible liquids shall be in accordance of Chapter 34 of the International Fire Code.
- _____ 11. The authorities are authorized to require this event and permit to be immediately revoked if they determine that the event is unsafe or hazardous to any person or persons.

SPECIAL CONDITIONS OF APPROVAL: _____

I hereby confirm that the above items and conditions have been explained to me and I will comply with them.

APPLICANT: _____ DATE: _____

APPROVED **DISAPPROVED** **REINSPECTION REQUIRED**

DATE: _____ TIME: _____ INSPECTOR: _____